

Angelo "Skip" Saviano  
Village President  
Gina Pesko  
Village Clerk  
Paul A. Volpe  
Village Manager  
Michael Durkin  
Village Attorney

**Trustees**  
Alan T. Kaminski  
Jeff Sargent  
Angela Stranges  
Anthony Del Santo  
Angelo J. Lollino  
Jonathan L. Zivojnovic

Mr. Matthew Cairo  
7115 North Ave. #256  
Oak Park, IL 60302

April 6, 2016

RE: Freedom of Information Act Request

Dear Mr. Cairo

The Village of Elmwood Park is in receipt of your April 4, 2016, Freedom of Information Act (5 ILCS 140/1 et seq.) ("FOIA") for the following records:

**"Please provide all building permits obtained and inspections, violations or criminal activity for 2947 N. 74<sup>th</sup> Ave, Elmwood Park, 60707..."**

Enclosed are records responsive to your request. However, please be advised that certain information in the records being provided has been determined to be exempt from disclosure under FOIA, and that information has been redacted from the records being provided.

**The Elmwood Park Police Department has no records pertaining to your request.**

Section 7 (1)(b) of FOIA provides that "private information" is exempt from disclosure. "Private information" is defined in FOIA as, "unique identifiers, including a person's social security number, driver's license number, employee id number, biometric identifiers, personal financial information, passwords or other access codes, medical records, home or personal telephone numbers, and personal email addresses." Section 7(1)(c) of FOIA provides that, "personal information contained within public records, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy is exempt from disclosure. Consequently, birthdates and other personal information, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy, such as the victim's name and identifying information, have been redacted from the records being provided.

In accordance with Section 9(a) of FOIA, you are hereby notified that you have the right to file a Request for Review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer with the Public Access Counselor at the Illinois Attorney General's Office.

You can file your Request for Review with the Public Access Counselor by writing to:

Sarah Pratt  
Public Access Counselor  
Office of the Attorney General  
500 South 2nd Street  
Springfield, Illinois 62706  
Fax: 217-782-1396  
E-mail: [publicaccess@atg.state.il.us](mailto:publicaccess@atg.state.il.us)

If you choose to file a Request for Review with the Public Access Counselor, you must do so within 60 calendar days of the date of this letter. Please note that you must include a copy of your original FOIA request and this letter when filing a Request for Review with the Public Access Counselor. You are also notified that you have the right to judicial review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer pursuant to Section II of FOIA.

Should you have any questions, please do not hesitate to contact my office.

Gina Pesko




Village Clerk  
Freedom of Information Officer  
708-452-3948

# Building Permits

## Inspection By Permit

User: ojones  
 Printed: 04/04/2016 - 4:17 PM  
 Sort By: Permit, Inspector, Scheduled Date/Time




Application No	Permit No	Tax Lot	Inspector	Inspector Phone	Inspection Type	Inspection Status	Internal?	Scheduled Date/Time	Required Date/Time	Actual Date/Time
0021380	151627	12-25-220-001-	BF Tech Plumbing	(847) 710-2227	Plmbg Undergrnd	Approved	No	10/27/2015 12:00 PM	10/27/2015 12:00 PM	
					Undergrnd aprvd, stack test aprvd, inside & out aprvd. Also did ejector & sump needs to pay \$200.00 Greg B&FP gp					
			BF Tech Plumbing	(847) 710-2227	Plmbg Rough	Approved	No	12/22/2015 10:30 AM	12/22/2015 10:30 AM	12/22/2015 10:30 AM
					Rough plumbing approved, stack test approved/B&F P Greg gd 12/22 PAID GD					
			BF Tech Plumbing	(847) 710-2227	Plmbg Final	Pending	No	03/17/2016 11:30 AM	03/17/2016 11:30 AM	03/17/2016 11:30 AM
					Final plmbg aprvd/Greg,B&Fp. dm					
0021381	151628	12-25-220-001-	BF Tech Elec	(847) 490-1443	Elec Rough	Approved	No	11/05/2015 10:30 AM	11/05/2015 10:30 AM	11/05/2015 10:30 AM
					Pass, 120/240 single phase 3 wire 100 amp serv for connection,Ok to fax ComEd/Zach B&Fe oj					
			BF Tech Elec	(847) 490-1443	Elec Inspt	Approved	No	12/21/2015 10:30 AM	12/21/2015 10:30 AM	12/21/2015 10:30 AM
					Rough elec aprvd/Zach,B&Fe. gp					
			BF Tech Elec	(847) 490-1443	Elec Final	Approved	No	03/17/2016 11:30 AM	03/17/2016 11:30 AM	03/17/2016 11:30 AM
					Final elec: Final elec aprvd/Randall,B&Fe. dm					
0021382	151629	12-25-220-001-			Hvac Final	Pending	No			
					2947 74TH AVE					

# Building Permits

## Inspection By Permit

User: ojonas  
 Printed: 04/04/2016 - 4:18 PM  
 Sort By: Permit, Inspector, Scheduled Date/Time



Application No	Permit No	Tax Lot	Inspector Phone	Inspection Type	Lot Address	Inspection Status	Internal?	Scheduled Date/Time	Required Date/Time	Actual Date/Time
0021342	151589	12-25-220-001-			2947 74TH AVE					
	BF Tech Elec	(847) 490-1443		Elec Rough	Pending	No	No	12/22/2015 10:30 AM	12/22/2015 10:30 AM	
	mwinicarc	(708) 452-3949		FramingRough	Reinspect	No	No	10/14/2015 10:30 AM	10/14/2015 10:30 AM	
	rbormann	(708) 452-3959		and prepr footng-Footing approved, framing not ready yet. Martin/gp	Approved	No	No	10/12/2015 11:30 AM	10/12/2015 11:30 AM	10/12/2015 11:30 AM
	rbormann	(708) 452-3959		Discussed project w/ contractor/Bob gd	Approved	No	No	12/23/2015 10:00 AM	12/23/2015 10:00 AM	
	rbormann	(708) 452-3959		and hvac- Frame,hvac,insulation approved. Bob/gp	Failed	No	No	03/17/2016 11:30 AM	03/17/2016 11:30 AM	03/17/2016 11:30 AM
	rbormann	(708) 452-3959		Final Building	Failed	No	No	03/17/2016 11:30 AM	03/17/2016 11:30 AM	03/17/2016 11:30 AM
				Exterior handrails to be graspable. Window at stairs to be protected-Address required on garage/Bob gd						

Notes

# Building Permits

## Inspection By Permit

User: oJones  
 Printed: 04/04/2016 - 4:19 PM  
 Sort By: Permit, Inspector, Scheduled Date/Time



Village of  
**Elmwood Park**

Application No	Permit No	Tax Lot	Inspector	Inspector Phone	Inspection Type	Inspection Status	Internal?	Scheduled Date/Time	Required Date/Time	Actual Date/Time
0014977	71163	12-25-220-001-			Framing Inspt	Pending	No	2947 74TH AVE		
					Elec Final	Pending	No			
					Final Inspt	Pending	No			
					PrepourGarageSlab	Reinspect	No	09/05/2007 10:00 AM		
					Prepour	Failed	No	09/06/2007 11:30 AM		
					3rd Inspection	Pending	No	09/10/2007 10:30 AM		
					Prepour Reinspt	Failed	No	09/12/2007 11:45 AM		

**Notes**

9/4/07:Cancelled per Danley.oj

Garage slab- Not aprvd. North wall of the garage is 17" too close to the north lot line. The apron is to be 2' from the north lot line. No one on site at time of insptn. RB

Aprvd, has movd garage back off easemnt/Jim oj

Per Bob prepour is not aprvd,called Danley & left message for them to contact Bob regarding this problem. dm

**Issue Number:** 19789  
**Citation Number:**  
**Issue Date:** 9/14/2015  
**Issue Type:** Affidavit Inspection  
**Issue Status:** In Progress

**Issue Description:**  
 Affid inspt.oj-2/23/16:Affid ltr snt.oj-3/17/16:Affid reinspt.oj

**Source Cust Number:** 000000

**Source Name:**

**Source Description:**

**Target Cust Number:** 038937

**Target Lot No:** 006462

**Target Name:** APEX HOME ADVISORS

**Target Lot Address:** 2947 74TH AVE

**Target Business Phone:** x0

**Target Home Phone:**

**Target Lot City, State:** ELMWOOD PARK, IL 60707

**Target Description:**

**Ordinance:**

**Notes:**

Demo in progress, 30 day extension./Vittorio oj

**Resolution Type:** Pending

**Resolution Notes:**

**User Defined:**

<b>Character 1:</b>	<b>Date 1:</b>	<b>Decimal 1:</b>	0.00	<b>Logical 1:</b>	False
---------------------	----------------	-------------------	------	-------------------	-------

<b>Character 2:</b>	<b>Date 2:</b>	<b>Decimal 2:</b>	0.00	<b>Logical 2:</b>	False
---------------------	----------------	-------------------	------	-------------------	-------

**Step:** 1 **Queue:** Code Admin

**User Name:** **Role:** **Action:**


**Scheduled Date:** **Completed Date:** 9/14/2015 **Action Description:**

**Scheduled Time:** 12:00 AM **Completed Time:** 4:00:00PM **Action Status:**

**Description:**

Schedule affdvt insp.

**Notes:**



Village of  
Elmwood Park

Issue Number: 19340  
Citation Number:  
Issue Date: 8/4/2015  
Issue Type: Smoke/CO Inspt  
Issue Status: Complete

Issue Description:  
Smk & CO inspt.oj-8/7/15:Smk & CO reinspt.oj

Source Cust Number: 000000

Source Name:

Source Description:

Target Cust Number: 006462

Target Lot No: 006462

Target Name:

Target Lot Address: 2947 74TH AVE

Target Business Phone:

Target Home Phone:

Target Lot City, State: ELMWOOD PARK, IL 60707

Target Description:

Ordinance:

Notes:

Smk & CO deters failed, 1-65 galon toter, water meter Ok/Vittorio oj-8/7/15:OK to trnsfr w/signed affid, water meter OK, 1-65 galon toter./Vittorio oj

Resolution Type: Completed

Resolution Notes:

User Defined:

Character 1:	Date 1:	Decimal 1:	0.00	Logical 1:	False
Character 2:	Date 2:	Decimal 2:	0.00	Logical 2:	False

Step: 1 Queue: Code Admin

User Name: Role: Action:

Scheduled Date: Completed Date: 8/3/2015 Action Description:

Scheduled Time: 12:00 AM Completed Time: 11:30:00AM Action Status:

Description:


Inspect for Smk & Co Installation

Notes:



# Village of Elmwood Park

**Issue Number:** 19121  
**Citation Number:**  
**Issue Date:** 7/14/2015  
**Issue Type:** Listing/TrnsfrStmp Inspt  
**Issue Status:** Sold



Village of  
**Elmwood Park**

**Issue Description:**  
 7/13: The daughter, [redacted] would like a copy of the listing report faxd to her @ [redacted] dm

**Source Cust Number:** 000000  
**Source Name:**  
**Source Description:**  
**Target Cust Number:** 006462      **Target Lot No:** 006462  
**Target Name:** [redacted]      **Target Lot Address:** 2947 74TH AVE  
**Target Business Phone:** [redacted]  
**Target Home Phone:** [redacted]      **Target Lot City, State:** ELMWOOD PARK, IL 60707  
**Target Description:**  
 Sister- / 8/10/15:Affid signed [redacted] FOR 9/14 INSPT.

**Ordinance:**

R2 S.F.H.

**Notes:**

Listing Inspection completed and entered in springbrook 07/14/15.-Vittorio

**Resolution Type:**

**Resolution Notes:**

**User Defined:**

Character 1:	Date 1:	Decimal 1:	Logical 1:
		0.00	False
Character 2:	Date 2:	Decimal 2:	Logical 2:
		0.00	False

Step: 1      Queue: Code Admin

User Name:      Role:      Action:

Scheduled Date:      Completed Date: 7/13/2015      Action Description:

Scheduled Time: 12:00 AM      Completed Time: 12:00 AM      Action Status:

**Description:**

Listing/Transfer Stamp Inspection

**Notes:**



Village of  
**Elmwood Park**

11 Conti Parkway Elmwood Park, IL 60707  
1-708-452-3920

**Pre-Sale Listing Inspection**  
**Narrative Report**

**OWNER(S) NAME:** [REDACTED]  
**ADDRESS:** 2947 North 74<sup>th</sup> Avenue  
**ZONING DIST:** R2  
**Agent:** Terry Dahlem-Coldwell Banker  
**Fax:** N/A  
**Email:** Terry.Dahlem@cbexchange.com

**DATE:** 07/14/2015  
**Phone:** [REDACTED]  
**Number of Units:** S.F.H.  
**Phone:** 847-682-9153

Seller required to have Smoke Alarms and Carbon Monoxide Detectors properly placed, installed and re-inspected prior to the issuance of the Transfer Stamp.

**Smoke Alarms:**

- Smoke alarm installation required "INSIDE" each sleeping room.
- Smoke alarm installation required in Furnace/utility area.

**Carbon Monoxide Detector:**

- Required within 15ft of any sleeping area.
- Carbon Monoxide Detectors MUST be installed within 15' feet of any area that is being used as sleeping quarters.

**At the time of inspection following deficiencies were observed:**

**Closet Lighting Fixture**

- Any Lighting fixture located in a closet shall have a protective covering.

**Handrails & Protective Guardrails:**

- Every interior and exterior flight of stairs having more than three (3) risers shall have a **continuous** graspable handrail on one (1) side **which returns to the wall**. Handrails shall not

be less than 30 inches high nor more than 42 inches high measured vertically above the nosing of the tread or above the finished floor of the landing or walking surface.

- Every open portion of a stair, landing, balcony, porch, deck, ramp, or other walking surface which is more than 30 inches above the floor or grade below, shall have guards no more than four (4) inches apart.
- Guards shall not be less than 30 inches high above the floor of the landing, balcony, porch, deck, or ramp or other walking surface.
- Every handrail and/or Protective guardrail shall be firmly fastened and capable of supporting normally imposed loads; said rails shall be maintained in good condition.

#### **House Numbers (Premises Identification):**

- Buildings shall have address numbers placed in a position to be plainly legible and visible from the street fronting the property and the alley way.
- House Numbers (Premises Identification): to be affixed to a garage, fence, or signage device, which clearly and visibly identifies the property's address **from the alleyway** Numbers shall be contrasting with background and a minimum of 4 inches in height.

#### **Chimney:**

- All chimneys, and similar appurtenances shall be maintained structurally safe, sound, bonneted and in good repair.

#### **Scrape & Paint Exterior (window frames and rear door and frame)**

- All exposed surfaces of metal or wood shall be protected from the elements, decay, or rust by periodic applications of weather-coating materials, such as paint or other similar surface treatments.
- All wooden exterior window framings shall be protected from the elements. Decayed rotted wood and any other defective surface conditions shall be corrected.

#### **Roof, Gutters & Downspouts: (home and garage)**

- Roof drainage systems shall be maintained in good repair, free of obstructions and functionally adequate to prevent dampness or deterioration in the walls or interior portion of the structure.

#### **Electrical:**

- Cover any open electrical boxes.
- All kitchen counter receptacles shall have tamper-proof GFCI protection.
- All Bathrooms shall contain at least one (1) tamper-proof GFCI receptacle.
- Laundry area shall contain at least one (1) tamper-proof GFCI receptacle.
- All Exterior, outdoor, and garage outlets shall have tamper-proof GFCI protection.
- Visible exterior ground rod required. Ground rod to be driven so that entire 8' is in contact with the earth (flush or below). All hardware and connectors must be approved for direct burial.

#### **Hot Water Tank:**

- Temperature-Pressure-Relief Valve (TPR) discharge pipe shall be of rigid metal piping, properly installed, and maintained on all water heaters.
- Supply lines may not be corrugated (flexible) copper. Solid metal rigid piping such as copper, galvanized metal or properly sized Stainless Steel Braided lines are acceptable.

**Other:**

- Power wash or remove awnings.
- Finish second floor bedroom and bathroom remodel.
- Remove flooring from basement.

**Comments:**

- Sellers agent has reported that the premises is being sold in “AS IS” condition. However; Seller is still required to have Smoke Alarms and Carbon Monoxide Detectors properly placed, installed, and re-inspected prior to the issuance of the Transfer Stamp.
- Thereafter all work to be completed via signed affidavit agreement between the Village of Elmwood Park and the Buyer.
- Permits required for all work.
- All work shall be performed by qualified competent licensed contractor(s).
- Contractor(s) MUST be registered with the Village of Elmwood Park, Show proof of insurance and show signed contractual agreement with the new property owner.
- **All appropriate plans and/or applications for building permits shall be applied for within 30 days of closing.**

**Issue Number:** 16803  
**Citation Number:**  
**Issue Date:** 8/5/2014  
**Issue Type:** Listing/TrnsfrStmp Inspt  
**Issue Status:** Complete



Village of  
**Elmwood Park**

**Issue Description:**

Lstng inspt.oj-R2- 1unit:Scrape/repaint all peeling surfaces, hndrls on all str, guards needd on all open str, coverd fxtrs needd, part of flr joists cut out t/b repaired, smk &CO deters needd, porch t/b resupported, temp jack not allowed, rear str need a landing, 2nd flr bthrm remodel reqres permits, dishwasher hookup t/b redone,

**Source Cust Number:** 000000

**Source Name:**

**Source Description:**

**Target Cust Number:** 006462

**Target Lot No:** 006462

**Target Name:**

**Target Lot Address:** 2947 74TH AVE

**Target Business Phone:**

**Target Home Phone:**

**Target Lot City, State:** ELMWOOD PARK, IL 60707

**Target Description:**

**Ordinance:**

FSBO/

**Notes:**

elec service needs an outside grd rod, remve BX into conduit, tamperproof GFI outlets all wet& outside locations, close up open elec boxes, no brkn/cracked wndws allowed, all t/b operable & have insect screens, evidence of wtr damage in bsmnt, raised flr may have t/b removed, fix foundation cracks & a wall leak at S.E. corner, chmny needs cap, permits reqred./Martin oj

**Resolution Type:** Completed

**Resolution Notes:**

**User Defined:**

<b>Character 1:</b>	<b>Date 1:</b>	<b>Decimal 1:</b>	0.00	<b>Logical 1:</b>	False
<b>Character 2:</b>	<b>Date 2:</b>	<b>Decimal 2:</b>	0.00	<b>Logical 2:</b>	False

**Step:** 1 **Queue:** Code Admin

**User Name:** **Role:** **Action:**

**Scheduled Date:** **Completed Date:** 7/30/2014 **Action Description:**

**Scheduled Time:** 12:00 AM **Completed Time:** 1:30:00PM **Action Status:**

**Description:**

Listing/Transfer Stamp Inspection

**Notes:**

## **Construction Permit No. 151591**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 09/02/2015**

To \_\_\_\_\_, Owner. Permission is hereby given **Trident Development & Construction, Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **DemoInterior** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No. \_\_\_\_\_

**Permit Fee: \$80.00**

**Valuation: \$3,500.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 151589**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 09/08/2015**

To **ARTHUR J. ...**, Owner. Permission is hereby given **Trident Development & Construction, Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **Addition Dormer** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No.

**Permit Fee: \$560.00**

**Valuation: \$51,700.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 151627**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 09/08/2015**

To \_\_\_\_\_, Owner. Permission is hereby given **Sian Plumbing, Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **Plmbg/Ktchn/Bth** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No. \_\_\_\_\_

**Permit Fee: \$210.00**

**Valuation: \$6,900.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 151628**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 09/08/2015**

To \_\_\_\_\_, Owner. Permission is hereby given **Trident Development & Construction, Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **Elec/Circuits** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No.

**Permit Fee: \$205.00**

**Valuation: \$3,800.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 151629**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 09/08/2015**

To \_\_\_\_\_, Owner. Permission is hereby given **Air Control Comfort, Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **Hvac/a/c&furnce** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No.

**Permit Fee: \$90.00**

**Valuation: \$4,100.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 71162**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 08/23/2007**

To \_\_\_\_\_ Owner. Permission is hereby given **Danley Lumber Co., Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **DemoGarage** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No. \_\_\_\_\_

**Permit Fee: \$0.00**

**Valuation: \$1,000.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

## **Construction Permit No. 71163**

This permit does not allow the use of Parkway or Street for any purposes. A Special Permit must be procured from the Building Commissioner. All debris must be removed by contractor or property owner.



Village of  
**Elmwood Park**

**By Authority of the Village of Elmwood Park**

**Issue Date: 08/23/2007**

To \_\_\_\_\_, Owner. Permission is hereby given **Danley Lumber Co., Inc.**, Contractor, to construct at Index No. **12-25-220-001-**. The work to be performed is **Garage** and is subject to all Ordinances of the Village of Elmwood Park. House No. **2947 74TH AVE.** Phone No.

**Permit Fee: \$0.00**

**Valuation: \$14,200.00**

This permit is revocable if there is any Deviation whatsoever from the Plans as Filed originally, unless written permission is given by the Code Administration Department for such Deviation.

**BUILDING PERMIT NO. 960234**

This permit does not allow the use of Parkway or Street for any purpose,  
A Special Permit must be procured from the Building Commissioner.  
All debris must be removed by contractor or property owner.

**VILLAGE OF ELMWOOD PARK**

Elmwood Park, Cook County, Illinois,

**By the Authority of the Village of Elmwood Park**

Issue date:5/8/1996

To . Owner. Permission is hereby given H.S. Roofing,  
Contractor. To construct at Index No. 12-25-220-001. The work to be performed is  
reroof with tear off/garage only, and is subject to all Ordinances of the Village of  
Elmwood Park.

House No. 2947 74th Ave. Telephone No.

Permit Fee \$27.50

Valuation 1100.00

This permit is revocable if there is any Deviation whatsoever  
from the Plans as Filed originally, unless written permission  
is given by this Department for such Deviation.

John F. Litrenta, Jr.

Director of Code Administration

Russell Macchione

Building Commissioner

DO NOT START WORK UNTIL PERMIT IS ISSUED.  
PERMIT MUST BE DISPLAYED ON JOB.