



Angelo "Skip" Saviano
Village President
Gina Pesko
Village Clerk
Paul A. Volpe
Village Manager
Michael Durkin
Village Attorney

Trustees
Alan T. Kaminski
Jeff Sargent
Angela Stranges
Anthony Del Santo
Angelo J. Lollino
Jonathan L. Zivojnovic

Mr. Hector Godinez
g.electric73@gmail.com

January 31, 2018

RE: Freedom of Information Act Request

Dear Mr. Godinez,

The Village of Elmwood Park is in receipt of your January 31, 2018, Freedom of Information Act (5 ILCS 140/1 et seq.) ("FOIA") for the following records:

**" (7350 Grand Av) 1) want to know if the building is up to code to open a restaurant.
2) If there is any violations that need to be fixed. Mainly that no major work has to be done"**

Attached are copies of the records you requested. However, please be advised that certain information in the records being provided has been determined to be exempt from disclosure under FOIA, and that information has been redacted from the records being provided.

Section 7 (1)(b) of FOIA provides that "private information" is exempt from disclosure. "Private information" is defined in FOIA as, "unique identifiers, including a person's social security number, driver's license number, employee id number, biometric identifiers (such as signatures), personal financial information, passwords or other access codes, medical records, home or personal telephone numbers, and personal email addresses." Section 7(1)(c) of FOIA provides that, "personal information contained within public records, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy is exempt from disclosure. Consequently, birthdates and other personal information, the disclosure of which would constitute a clearly unwarranted invasion of personal privacy, such as a victim's name and identifying information, have been redacted from the records being provided.

In accordance with Section 9(a) of FOIA, you are hereby notified that you have the right to file a Request for Review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer with the Public Access Counselor at the Illinois Attorney General's Office.

You can file your Request for Review with the Public Access Counselor by writing to:

Sarah Pratt
Public Access Counselor
Office of the Attorney General
500 South 2nd Street

Springfield, Illinois 62706
Fax: 217-782-1396
E-mail: publicaccess@atg.state.il.us

If you choose to file a Request for Review with the Public Access Counselor, you must do so within 60 calendar days of the date of this letter. Please note that you must include a copy of your original FOIA request and this letter when filing a Request for Review with the Public Access Counselor. You are also notified that you have the right to judicial review regarding the decision made by the Village of Elmwood Park Freedom of Information Officer pursuant to Section II of FOIA.

Should you have any questions, please do not hesitate to contact my office.

Gina Pesko



Village Clerk
Freedom of Information Officer
708-452-3948

Issue Number: 22409
Citation Number:
Issue Date: 1/25/2017
Issue Type: Business License Inspec
Issue Status: Approved



Issue Description:
 Bus. Lic. Inspt, (Anoki Pizza) /Bob, Hlth, B&F elec & plmbg. dm
Source Cust Number: 000000

Source Name:
Source Description:

Target Cust Number: 020625 **Target Lot No:** 006876
Target Name: **Target Lot Address:** 7530 GRAND
Target Business Phone: (708) 456-9424
Target Home Phone: **Target Lot City, State:** ELMWOOD PARK, IL 60707

Target Description:
 3/7/17: l/m for to sched Health insp.gp

Ordinance:
 9/28/16: FAILED: back dr lght needs globe, fix recptcls attachd to ktchn counter where it stubs dwn from ceiling, need 3ft clearnce for panels, jumper watr metr, provide gfi protctn for ktchn recpts counter area, label all ckt brkrs&disconncts, remv abandond conduit abv warming oven, fix brkn motor cords&ktchn freezr, reattach recpts next to panel, provide lockable fire alrm brkr/Randall, B&Fe. oj

Notes:
 Seating for more than 8 reqrs 2 handicap bthrms, existing bthrm is reqrd t/b handicap accessible, ceiling tiles damagd & stained need t/b replcd, ceiling vents t/b cleaned or replcd, rusted water tank flue needs t/b replcd/Bob. oj **Final plmb aprvd for license/Greg, B&Fp. oj 1/25/17:** Elec: FAILED: Cover junctn bx on outside sign, id all ckts&disconncts, 3ft clear space in frnt of elec panel reqrd, jumper watr metr&hot watr tank, light over rear dr not suitable for locatn, hav ladder available for ceiling insp/Randall B&Fe. g

Resolution Type: Completed
Resolution Notes:

1/25: Bus.lic reinsp, Bldg: Bldg portion of bus.lic aprvd, aprvl needd from plmb, elec, hlth&fire/Bob.gp 1/31: Reinsp Elec: Items correctd, elec insp aprvd, abv ceiling Ok/Randall, B&Fe. 1/24&3/9/17: Paul of Hlth signed aprvl. dm

User Defined:

Character 1:	Date 1:	Decimal 1:	Logical 1:
Character 2:	Date 2:	Decimal 2:	Logical 2:
		0.00	False
		0.00	False

Step: 1 **Queue:** Code Admin
User Name: **Role:** **Action:**
Scheduled Date: **Completed Date:** 9/23/2016 **Action Description:**
Scheduled Time: 12:00 AM **Completed Time:** 1:00:00PM **Action Status:**
Description:
 Business License Insp.
Notes: